



## Fire Drill Official Report

<b>Building:</b> Al Ain Juniors school	<b>Location:</b> IndianSystem	<b>Assembly Point:</b> 3 ( AP3)
<b>Date:</b> Nov 24 2024	<b>Time:</b> 10:45 AM	<b>Type:</b> Planned

### List of participating area:

AJI Primary floor Grade 1-6 & AJI Secondary Grade 7-12

	Yes	No
Was alarm heard throughout the building?	*	
Were all alarm devices operating correctly? IF NO, note locations in additional comments.	*	
Did Staff and Student evacuate the building? IF NO, note classroom / office numbers in additional comments.	*	
Did Staff and Student assemble in designated areas? IF NO, specify why in additional comments.	*	

<b>Overall effectiveness of the drill:</b>	<b>AJI Ground floor Grade 1-6</b>	<b>Good</b>	<b>Fair</b>	<b>Poor</b>
Speed of evacuation	*			
Effectiveness of procedures	*			
Communication during drill	*			

Total time to evacuate: 2 minutes

Time all clear given: After 10 seconds

Comments and Recommendations : Excellent teamwork and coordination ensured a swift evacuation within the required timeframe

<b>Overall effectiveness of the drill:</b>	<b>AJI First floor Grade 7-12</b>	<b>Good</b>	<b>Fair</b>	<b>Poor</b>
Speed of evacuation	*			
Effectiveness of procedures	*			
Communication during drill	*			

Total time to evacuate: 2 minutes and 20 Seconds

Time all clear given: After 10 seconds

Comments and Recommendations: Students followed instructions diligently, contributing to a smooth and timely evacuation

**Report Prepared by:** Sandeep Sadasivan

**Position:** HSE Officer

## Fire Drill Official Report

<b>Building:</b> Al Ain Juniors School	<b>Location:</b> British System	<b>Assembly Point:</b> 1 ( API )
<b>Date :</b> Nov 21, 2024	<b>Time:</b> 10:45 AM	<b>Type:</b> Planned

### List of participating area:

AJ British System primary Grade 02, 04, 06-C and 06-D & AJ British System secondary boys (07-12) AJI KG2 and all admin offices AJB

	Yes	No
Was alarm heard throughout the building?	*	
Were all alarm devices operating correctly? IF NO, note locations in additional comments.	*	
Did Staff and Student evacuate the building? IF NO, note classroom / office numbers in additional comments.	*	
Did Staff and Student assemble in designated areas? IF NO, specify why in additional comments.	*	

Overall effectiveness of the drill: Grade 02 4,6C&D and AJI KG-2 and admin offices	Good	Fair	Poor
Speed of evacuation	*		
Effectiveness of procedures	*		
Communication during drill	*		

Total time to evacuate: **3 minutes.**

Time all clear given: **After 10 seconds**

Comments and Recommendations : AJB Primary, KG, and other office staff successfully reached the assembly point within 3 minutes, demonstrating commendable calmness and efficiency in doing so.

Overall effectiveness of the drill: AJB Secondary (Boys 07-12), AJB primary 06A & 6B	Good	Fair	Poor
Speed of evacuation			*
Effectiveness of procedures	*		
Communication during drill	*		

Total time to evacuate: **: 4 minutes and 20 Seconds**

Time all clear given: **After 10 seconds**

Comments and Recommendations: The evacuation time needs improvement and should not exceed 3 minutes, as per ADEK standards. Students showed a lack of urgency in evacuating and reaching the assembly point. Bottlenecks were observed on the stairs, highlighting the need for a review of the escape route to enhance efficiency.

**Report Prepared by:** Sandeep Sadasivan

**Position:** HSE Officer



## Fire Drill Official Report

<b>Building:</b> Al Ain Juniors school	<b>Location:</b> AJB G 1 & 3, AJB block F & KG	<b>Assembly Point:</b> 2 ( AP2 )
<b>Date :</b> Nov 21 2024	<b>Time:</b> 10:45 AM	<b>Type:</b> Planned

### List of participating area:

AI British and Indian System ( KG Area), AJB Grade 07-12 (Girls) & AJB G1 & 3 ( Blk-B)

	Yes	No
Was alarm heard throughout the building?	*	
Were all alarm devices operating correctly? IF NO, note locations in additional comments.	*	
Did Staff and Student evacuate the building? IF NO, note classroom / office numbers in additional comments.	*	
Did Staff and Student assemble in designated areas? IF NO, specify why in additional comments.	*	

Overall effectiveness of the drill: <b>AJB and AJI ( KG Area ), AJB Grade 1-3</b>	Good	Fair	Poor
Speed of evacuation	*		
Effectiveness of procedures	*		
Communication during drill	*		

Total time to evacuate: **02:50 minutes**

Time all clear given: **After 10 seconds**

Comments and Recommendations : The evacuation time met ADEK standards, thanks to the teachers' excellent guidance in directing everyone to the assembly area..

Overall effectiveness of the drill: <b>AJB first floor Block- F high school</b>	Good	Fair	Poor
Speed of evacuation		*	
Effectiveness of procedures	*		
Communication during drill	*		

Total time to evacuate: **3 minutes & 20 seconds**

Time all clear given: **After 10 seconds**

Comments and Recommendations: The evacuation time exceeded the target by 20 seconds, indicating a need for additional practice.

**Report Prepared by:** Sandeep Sadasivan

**Position:** HSE Officer



## Fire Drill Photos





